


ADDENDUM #2
TO THE
DRAWINGS, PROJECT MANUAL, AND TECHNICAL SPECIFICATIONS
FOR THE
OLD SOUTH HAVEN STORMWATER IMPROVEMENTS PROJECT
PORTER COUNTY, SOUTH HAVEN, INDIANA
SEPTEMBER 27, 2018

The information contained in this Addendum shall become a part of the drawings and specifications the same as if originally incorporated therein. The Drawings dated August 30, 2018 and the Project Manual dated August 2018 as prepared by DLZ Indiana, LLC shall remain in their entirety, except as modified by this Addendum. The items herein shall supersede information in the Drawings and Project Manual.

Each bidder shall acknowledge receipt of this Addendum No. 2 in their Bid.

CERTIFIED BY:

ANTHONY J. KENNING, P.E.
REGISTERED PROFESSIONAL ENGINEER
STATE OF INDIANA NO. 10000097



A handwritten signature in black ink, appearing to read "Anthony J. Kenning", written over the bottom portion of the professional engineer seal.

SPECIAL PROVISIONS AND TECHNICAL SPECIFICATIONS

- A. Within the Storm Sewer, (Diameter) In. Section, Item 36, Page 124-125, **DELETE** Modifications Paragraph C and **REPLACE** with the following: *The pipe type heading east out of Structure No. 17 at the north end of Baltimore Road shall be zinc coated corrugated steel pipe in accordance with INDOT Section 908. Pipe shall be banded and coupled together with existing pipe per manufacturer's recommendations.*

END OF ADDENDUM #2

M:\proj\1864\1336 POCO - OSH\Addenda\Addendum #2\1 - Addendum No. 2 to POCO OSH (Northeast Area).doc